

BUILDING SAFETY CERTIFICATE

The building of Him Gurukul International School Bhalat PO Harsour Tehsil Barsar Distt. Hamirpur (HP), is inspected along with concerned Junior Engineer. The building has neither been designed nor constructed by this department. No earthquake resistant norms have been adopted for this building. No structure drawing approved by the competent Government Agency have been produced. The structure is a Non Engineering structure. Hence the structure safety of this building can not be ensured specially from earthquake point of view. The year of construction of this building is 2017 as intimated by the concerned School owner. This department will not be responsible for any type of loss of life and property etc., if this structure falls under any circumstances. However as per visual appearance, the building seems safe for functioning for the year/academic session 2024-2025 and 2025-2026.


Junior Engineer,
HPPWD Section Barsar


Assistant Engineer
HPPWD Sub-Division
Barsar.


Executive Engineer
Barsar Division
HPPWD. Barsar